



防 爆 电 气 设 备
Electrical Apparatus for Explosive Atmospheres

防 爆 合 格 证

CERTIFICATE OF CONFORMITY

编 号: CNEx04.211U
Serial No.

制 造 单 位
Manufacturer

CCG Cable Terminations (Pty) Ltd

样 品 名 称
Name of Product

Reducers, Adaptors and Blanking plugs(Metal and Non-metal)

型 号 规 格
Type of Product

See Attached Page

防 爆 标 志
Marking

ExdI/ IIC(Zone1, 2)/ e II (Zone1, 2)/ DIP A21,22

产 品 标 准
Standard

—

总 装 图 号
Drawing No.

E.00.00.90.100, E.00.00.90.400, E.00.00.90.200,
E.40.00.24.200/1, E.00.00.01

经对上述产品图样及技术文件的审查和样品的检验, 确认符合下列标准:

The drawings, technical documents and the samples are verified and certified according to standard(s) for safety as below:

GB3836.1-2000 Electrical apparatus for explosive gas atmospheres-Part 1:General requirements

GB3836.2-2000 Electrical apparatus for explosive gas atmospheres-Part2: Flameproof enclosure "d"

GB3836.3-2000 Electrical apparatus for explosive gas atmospheres- Part3: Increased safety "e"

GB12476.1-2000 Electrical apparatus for use in the presence of combustible dust-Part 1-1: Electrical apparatus protected by enclosures and surface temperature limitation-Specification for apparatus

记 事
Note

See Attached Page

本证有效期

From Mar 9, 2004 to Mar 8, 2009

Valid Date

中心主任
Director



国家防爆电气产品质量监督检验中心

CHINA NATIONAL QUALITY SUPERVISION AND TEST
CENTRE FOR EXPLOSION PROTECTED ELECTRICAL PRODUCTS



颁发日期

March 9, 2004

Issue Date

年 月 日

注: 本证仅对符合送检样品的产品有效, 证书持有者有责任保证产品符合标准规定。

Note: This certificate is only valid for the products which identify with the sample(s) tested and verified. Holder(s) of this certificate have the responsibility to ensure the products complying with relevant standard(s).

地址: 河南省南阳市仲景北路20号 邮政编码: 473008 电话: 0377-3258564, 3258555 传真: 0377-3208175, 3225471
Address: Nanyang, Henan, P. R. China Post code: 473008 Tel: 0377-3258564, 3258555 Fax: 0377-3208175, 3225471
E-mail: cqst@cn-ex.com Http:// www.china-ex.com



防 爆 电 气 设 备
Electrical Apparatus for Explosive Atmospheres

防爆(检验)合格证附页

APPENDIX TO CERTIFICATE OF CONFORMITY

证书编号: CNEx04.211U

Serial No.

1. The products have been certified by UL International Demko, Certificate No.: DEMKO 01 ATEX130325X /Report No.: 130325-01;
2. The products should be fitted into the Ex-equipment;
3. This certificate can stand for the following products:
Marking: ExdI/ IIC(Zone1, 2)/ e II (Zone1, 2)/ DIP A21,22
The blanks are available with Metric (M16,M20,M25,M32,M40,M50,M63,M75)
NPT(1/2", 3/4", 1", 1 1/4", 1 1/2", 2", 2 1/2") PG (9,11,13.5,16,21,29,36,42,48) entry threads.
The reducers are machined into a metric male thread (from M16 to M63) at one end and a female metric thread (from M16 to M50) at the other.
The range of Adaptors are machined into a male thread at one end and a female thread at the other. The threads may be Pg to Metric, NPT to Metric or Metric to Metric.
The range of adaptors and reducers are machined into a male metric thread (from M16 to M75) at one end and a female NPT thread (from 1/4" to 3") at the other.
4. If mounted in flameproof enclosures, make sure that at least 5 threads are engaged and that the depth of engagement for enclosures smaller than 100 cm³ are at least 5mm and for enclosures larger than 100 cm³ at least 8mm;
5. The temperature classification is to be evaluated when installed.

中心主任
Director



国家防爆电气产品质量监督检验中心
CHINA NATIONAL QUALITY SUPERVISION AND TEST
CENTRE FOR EXPLOSION PROTECTED ELECTRICAL PRODUCTS



颁发日期
Issue Date

March 9, 2004

年 月 日